

DATE: October 27, 2016

ADDENDUM NO. 1: New Tennis Court Nos. 5 & 6 at the Jumbo Evans Sports Park EARTHWORK PACKAGE

BID DATE: November 1, 2016

STRUCTURAL ENGINEER: PICKETT, KELM & ASSOCIATES, INC.

TO: ALL BIDDERS



This addendum forms a part of the contract documents of this project. All items in the drawings and specifications referenced herein shall be supplemented and modified as follows:

FRONT END DOCUMENTS – Page 4

1. Remove and replace “prior to August 31, 2016” with “ in 60 Calendar Days” in the following paragraph:

Contract Time is of essence and all Work shall be completed prior to August 31, 2016, in accordance with the Bid Form, Section 200. Liquidated damages are one hundred dollars (\$100) per day, in accordance with the Bid Form, Section 200.

STRUCTURAL DRAWINGS

Item No. S1.01 DRAWING S-1: **REVISE** Earthwork Note 5 as follows:

THE PROJECT AREA SHALL BE CLEARED, GRUBBED AND STRIPPED OF ALL EXISTING VEGETATION, TOPSOIL, CONCRETE, ASPHALT AND OTHER ORGANIC MATERIAL OR DEBRIS AND EXCAVATED TO A MINIMUM DEPTH OF 42 INCHES BELOW THE EXISTING GRADE TO A MINIMUM DISTANCE OF 3 FEET OUTSIDE THE LIMITS OF THE TENNIS COURT SLAB AS SHOWN ON DRAWING S-3 – SITE AND GRADING PLAN. THE EXCAVATED MATERIAL SHALL BE LOADED, HAULED OFF AND DISPOSED OF OFF-SITE.

CONTRACTOR SHALL INCLUDE THE COST OF LOADING, HAULING AND DISPOSING OF 70 CUBIC YARDS OF SOIL AND LIMESTONE PARTICLES, WITH PARTICLE SIZES UP TO 42 INCHES X 42 INCHES X 30 INCHES, PILED TO THE SOUTH SIDE OF THE EXISTING SEPTIC SYSTEM.

Item No. S1.02 DRAWING S-1: **ADD** the following to the bottom of Earthwork Note 9:

THE USE OF ALTERNATE SELECT STRUCTURAL FILL WILL NOT BE PERMITTED UNLESS THE REQUIREMENTS IN THE PARAGRAPH ABOVE ARE MET.

Item No. S1.03 DRAWING S-3 – SITE AND GRADING PLAN – **ADD** the following plan note:

SLOPES AT SIDES OF THE TENNIS COURT PAD SHALL NOT EXCEED 4H:1V.

END OF ADDENDUM NO. 1